



2021 Consumer Confidence Report Data

MUKWONAGO WATERWORKS, PWS ID: 26802094

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, o hable con alguien que lo entienda.

Dlaim ntawv tshaabzu nuav muaj lug tseemceeb heev nyob rua huv kws has txug cov dlej mej haus. Kuas ib tug paab txhais rua koj, los nrug ib tug kws paub lug thaam.

Water System Information

We are proud to announce that Mukwonago Water Works had no violations in 2021. If you would like to know more about the information contained in this report, please contact Wayne Castle at (262) 363-6416, or by email at wcastle@villageofmukwonago.com

Source of Water: Mukwonago Waterworks currently operates 5 groundwater wells to provide water to the Village. We operate 2 deep wells, and 3 shallow wells. Since the deep wells contain radium, we blend that water with water from the shallow wells that contain little to no radium. This ensures that our water meets limits set by the U.S. EPA. In 2019 Mukwonago Waterworks constructed an iron filtration plant at one of our wells that produces a significant amount of iron present in our water. Our goal is to provide the best water that we can to our customers.

Groundwater Protection Program and System Improvements: A Well Head Protection Plan (WHPP) was prepared to identify any potential contaminants to the wells and to project the area surrounding each well. The enforcement aspect of the WHPP is achieved by an Ordinance which identified the permitted and prohibited uses for the area surrounding the wells.

Hydrant Flushing: Mukwonago Waterworks flushes hydrants annually to help remove iron deposits from the distribution system. The dates are published on the Village's website. When we do flush, customers may experience discolored water. Avoid doing laundry when the flushing process is occurring.

Sprinkling sewer credit: The most common period of sprinkling lawns and summer water use is from June thru August. The Village uses the March through May billing period to establish the "maximum billable sewer volume" for issuing bills for the summer quarter. If a pool needs to be filled, wait until after June 5th, to avoid the sewer charge.

Check your meter: To see if you have a water leak, turn off all uses for water and look at your water meter. If everything is off, the meter should not be recording any flow. If it is, you are paying for water that's being wasted. If it is moving, look for the source. If you can't find it, call us at 262-363-6416 and we'll try to help find the problem. Most leaks come in the form of running toilets. You may not always hear a running toilet and the water goes down the drain, so the leak is not as obvious. Here is a link that provides great information on how we use water and finding leaks <https://www.epa.gov/watersense>.



Water Sample Test Results: Mukwonago Water Works follows the sampling and testing requirements established by the Wisconsin Department of Resources. The water supplies are tested, to ensure that the water provided to the community complies with safe drinking water standards.

Opportunity for input on decisions affecting your water quality

Committee of the Whole meetings are held the first Wednesday of every month. Village Board meetings are held the third Wednesday of every month. All meetings are held at the Village Hall at 440 River Crest Court in Mukwonago. Check the Village website at <https://www.villageofmukwonago.com/> for specific meeting dates and agendas.

Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Environmental Protection Agency's safe drinking water hotline (800-426-4791).

Source(s) of Water

SOURCE ID	SOURCE	DEPTH (IN FEET)	STATUS
3	Groundwater	1500	Active
4	Groundwater	1500	Active
5	Groundwater	143	Active
6	Groundwater	105	Active
7	Groundwater	180	Active

To obtain a summary of the source water assessment please contact, Wayne Castle at (262) 363-6416.

Educational Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:



- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally- occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which shall provide the same protection for public health.

Definitions

Term	Definition
AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
HAL	Health Advisory Level: The concentration of a contaminant which, if exceeded, poses a health risk and may require a system to post a public notice.
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine, if possible, why an E. coli MCL violation has occurred or why total coliform bacteria have been found in our water system, or both, on multiple occasions.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MFL	million fibers per liter



Term	Definition
MRDL	Maximum residual disinfectant level: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum residual disinfectant level goal: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
mrem/year	millirems per year (a measure of radiation absorbed by the body)
NTU	Nephelometric Turbidity Units
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/l)
ppb	parts per billion, or micrograms per liter (ug/l)
ppt	parts per trillion, or nanograms per liter
ppq	parts per quadrillion, or picograms per liter
SMCL	Secondary drinking water standards or Secondary Maximum Contaminant Levels for contaminants that affect taste, odor, or appearance of the drinking water. The SMCLs do not represent health standards.
TCR	Total Coliform Rule
TT	Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.

Detected Contaminants

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables below along with the sample date.



Disinfection Byproducts

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
HAA5 (ppb)	DBP1	60	60	9.7	9.7		No	By-product of drinking water chlorination
TTHM (ppb)	DBP2	80	0	13.8	13.8		No	By-product of drinking water chlorination

Inorganic Contaminants

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
ARSENIC (ppb)		10	n/a	0	0 - 0	7/13/2020	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
BARIUM (ppm)		2	2	0.086	0.051 - 0.086	7/13/2020	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE (ppm)		4	4	0.6	0.3 - 0.6	7/13/2020	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NICKEL (ppb)		100		4.3000	1.5000 - 4.3000	7/13/2020	No	Nickel occurs naturally in soils, ground water and surface waters and is often used in electroplating, stainless steel and alloy products.



NITRATE (NO3-N) (ppm)	10	10	0.82	0.05 - 0.82		No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
SELENIUM (ppb)	50	50	1	0 - 1	7/13/2020	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
SODIUM (ppm)	n/a	n/a	110.00	25.00 - 110.00	7/13/2020	No	n/a

Contaminant (units)	Action Level	MCLG	90th Percentile Level Found	# of Results	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
COPPER (ppm)	AL=1.3	1.3	0.1400	0 of 20 results were above the action level.	10/7/2020	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD (ppb)	AL=15	0	2.60	0 of 20 results were above the action level.	10/6/2020	No	Corrosion of household plumbing systems; Erosion of natural deposits

Radioactive Contaminants

Contaminant (units)	Site	MCL	MCLG	Level Found	Range	Sample Date (if prior to 2021)	Violation	Typical Source of Contaminant
COMBINED URANIUM (ug/l)		30	0	0.8	0.8		No	Erosion of natural deposits



Contaminants with a Health Advisory Level or a Secondary Maximum Contaminant Level

The following tables list contaminants which were detected in your water and that have either a Health Advisory Level (HAL) or a Secondary Maximum Contaminant Level (SMCL), or both. There are no violations for detections of contaminants that exceed Health Advisory Levels, Groundwater Standards or Secondary Maximum Contaminant Levels. Secondary Maximum Contaminant Levels are levels that do not present health concerns but may pose aesthetic problems such as objectionable taste, odor, or color. Health Advisory Levels are levels at which concentrations of the contaminant present a health risk.

Contaminant (units)	Site	SMCL (ppm)	HAL (ppm)	Level Found	Range	Sample Date (if prior to 2021)	Typical Source of Contaminant
ALUMINUM (ppm)		0.05	0.2	0.01	0.00 - 0.01	1/30/2017	Runoff/leaching from natural deposits
CHLORIDE (ppm)		250		100.00	48.00 - 100.00	1/30/2017	Runoff/leaching from natural deposits, road salt, water softeners
IRON (ppm)		0.3		0.43	0.08 - 0.43	1/30/2017	Runoff/leaching from natural deposits, industrial wastes
MANGANESE (ppm)		0.05	0.3	0.03	0.02 - 0.03	1/30/2017	Leaching from natural deposits
ZINC (ppm)		5		0.02	0.00 - 0.02	1/30/2017	Runoff/leaching from natural deposits, industrial wastes

Health effects for any contaminants with MCL violations/Action Level Exceedances/SMCL exceedances/HAL exceedances

Contaminant Health Effects

IRON Waters containing iron in quantities above the SMCL are not hazardous to health but may be objectionable for taste, odor, or color.

Additional Health Information

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Mukwonago Waterworks is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.