



Village of Mukwonago

Office of the Water and Sewer Utilities

440 River Crest Court, Mukwonago, Wisconsin 53149
Tel. (262) 363-6416 | Fax: (262)363-0552

Sanitary Sewer Overflow Occurred on 1-23-24

On 1-23-24 from approximately 6:00pm to 1-24-24 at 10:00am, the Village of Mukwonago experienced a sanitary sewer overflow near 601 Main Street. Approximately 100 gallons of sewage overflowed to a gravel driveway area at this location. No homes or residents were affected by this overflow and no health risks were determined.

The overflow occurred due to a broken air release pipe attached to the sanitary sewer force main in this area. The pipe has been repaired and is currently back in operation.

Please contact me with any questions or concerns.

Thank you,

Wayne Castle

Wayne Castle
Utilities Director

wcastle@villageofmukwonago.gov